

Notification of Potential Unsafe Condition

June 23, 2009

This dwelling contains the following condition(s), as noted on the checklist below, that have a potential to be unsafe, or could be an indicator of past unsafe operation of fuel-burning appliances.

- Noticeable odor of gas
- Soot or burned appearance on the exterior of:
 - Furnace Water heaterindicating previous flame "rollout" or backdraft of the appliance
- Potentially blocked chimney
- Missing, disconnected, or corroded vent connector on
 - Furnace Water heater
- Unvented combustion heating appliance

Notes:

It is recommended that the building owner or occupant request immediate service by a qualified technician to evaluate the situation and recommend corrective action as needed. At least one carbon monoxide alarm is recommended in every home whenever combustion equipment is present.

Home Address:

City _____ State _____ Zip _____

Auditor _____ Owner _____

Signature _____ Signature _____

Date _____ Date _____