

## Changes to Draft PDS-02 of BSR/RESNET/ICC 380-2016 Addendum A-201x

***Infiltration Volume***<sup>23</sup> – The sum of the Conditioned Space Volume and additional adjacent volumes in the dwelling unit that meet the following criteria:

- Crawlspace, when the access doors or hatches between the crawlspace and Conditioned Space Volume are open during the enclosure airtightness test (Section 3.2.3),
- Attics, when the access doors or access hatches between the attic and Conditioned Space Volume are open during the enclosure airtightness test (Section 3.2.4),
- ~~Vented crawlspaces,~~
- ~~Garages,~~
- Basements, where the doors between the basement and Conditioned Space Volume are open during the enclosure airtightness test (Section 3.2.5).