

## How to Verify Manual-J Accuracy & Properly Select Equipment

RESNET Conference - 2014

Isaac Savage, CEM  
Training Development Director  
Home Energy Partners



## ABOUT US



**Home Energy Partners develops and distributes training curriculum for the HVAC and Building Performance contracting industry.**

Topic include:

- Manual-J, S, D, & T
- HVAC Design Software (Wrightsoft & Elite)
- RESNET HERS Training
- BPI Training
- Home Performance Contracting




## WHAT WE'LL COVER...

- Design is required by...
- Common challenges
- The variables that matter
- Reports for Wrightsoft & Elite
- Manual-S basics
- Start-to-finish equipment selection example
- Demo of a Manual-S spreadsheet tool



## WHO REQUIRES LOAD CALCULATIONS?

- Required by Programs
  - ENERGY STAR Version 3
  - LEED for Homes
  - Utility Rebates
- Required by Building Code!
  - 2006, 2009, 2012 IECC
- Many programs require 3<sup>rd</sup> party review.



## COMMON CHALLENGES

- Tracking down the information in reports.



- Some variables don't show up on the reports.
- Sometimes things just look funny on the reports.  
"What does that mean?"



## VARIABLES THAT MATTER

- Design conditions
- Envelope details
- Ductwork specifications
- Internal Loads
- Infiltration
- Ventilation




# DESIGN CONDITIONS (OUTDOOR)

**Table 1A**  
Outdoor Design Conditions for the United States

Location	Elevation Feet	Latitude Degrees North	Winter			Summer			
			Heating 99% Dry Bulb	Cooling 1% Dry Bulb	Coincident Wet Bulb	Design Grains 55% RH	Design Grains 50% RH	Design Grains 45% RH	Daily Range (DR)
<b>Texas</b>									
Abilene AP	1790	32	22	97	71	2	9	15	M
Alice AP	178	27	34	98	77	37	44	50	M
Amarillo AP	3604	35	12	94	66	-17	-10	-4	H
Austin AP	597	30	30	96	74	22	29	35	M
Bay City	45	29	33	94	77	59	66	72	M
Beaumont	16	30	32	92	79	61	68	74	M

Outdoor design conditions come from Table 1-A



# DESIGN CONDITIONS (INDOOR)




Figure 3-2



## ENVELOPE DETAILS

- Walls/Doors


- Sqft, U-value, # of Types



- Windows


- Sqft, Orientation, Overhangs, U-value & SHGC

ENERGY STAR Qualified	
Low-E Windows	
World's Best Windows Co.	
ENERGY STAR Qualified	
ENERGY PERFORMANCE RATINGS	
0.35	0.32
ADDITIONAL PERFORMANCE RATINGS	
0.51	0.2



- Floors/Ceilings

- Sqft, U-value, # of Types



- Orientation



## DUCTWORK SPECIFICATIONS

- Inputs

- Location (temperature of that space)
- Sqft surface area (default values are commonly used)
- Leakage (uses tables, not CFM@25pa)
- Insulation levels
- Supply discharge temp (heating)

- Unfortunately, these inputs **don't show up in the reports**. Reports only show the resulting duct loads.



# EVALUATING DUCT LOADS

**Summary of Default Duct Load Tables**

Location	Supply System Geometry <sup>1</sup>	Return System Geometry <sup>1</sup>	Table Number
Unvented attic or attic knee wall space above 16A ceiling (150 °F attic when OAT = 95 °F).	Radial with outlets in center of rooms.	Radial, 400 CFM per return, returns close to air handler.	7A-R
	Trunk and branch with outlets in center of rooms.	Trunk and branch, 400 CFM per return, returns close to air handler.	7A-T
<b>Vented attic or attic knee wall space above 16B ceiling (130 °F attic when OAT = 95 °F).</b>	Radial with outlets in center of rooms.	Radial, 400 CFM per return, returns close to air handler.	7B-R
	Trunk and branch with outlets in center of rooms.	Trunk and branch, 400 CFM per return, returns close to air handler.	7B-T
	Radial with outlets in center of rooms.	Single ceiling return close to air handler.	7A-AE
	Radial with outlets in center of rooms.	Grille at air handler, return in closet door.	7B-AE
	<b>Trunk and branch with outlets in center of rooms.</b>	<b>Grille at floor of conditioned space, return riser to attic air handler.</b>	<b>7C-AE</b>
Vented attic or attic knee wall space above 16C ceiling (120 °F attic when OAT = 95 °F).	Radial with outlets in center of rooms.	Radial, 400 CFM per return, returns close to air handler.	7C-R
	Trunk and branch with outlets in center of rooms.	Trunk and branch, 400 CFM per return, returns close to air handler.	7C-T
Vented attic or attic knee wall space above 16D ceiling (110 °F attic when OAT = 95 °F).	Radial with outlets in center of rooms.	Radial, 400 CFM per return, returns close to air handler.	7D-R
	Trunk and branch with outlets in center of rooms.	Trunk and branch, 400 CFM per return, returns close to air handler.	7D-T
Vented attic or attic knee wall space above 16E ceiling (105 °F attic when OAT = 95 °F).	Radial with outlets in center of rooms.	Radial, 400 CFM per return, returns close to air handler.	7E-R
	Trunk and branch with outlets in center of rooms.	Trunk and branch, 400 CFM per return, returns close to air handler.	7E-T



# EVALUATING DUCT LOADS

**Table 7C-AE - Trunk and Branch Supply System in 16E**

7C-AE Ambient drybulb temperature = Outdoor db + 11 (heating) and Outdoor db + 35 (cooling) Supply location = Attic Duct leakage CFM per SqFt of duct surface area (supply / return) = 0.05/0.05; 0.05/0.15; 0.12/0.24; 0.24/0.47; 0.35/0.70

Base Case Heat Loss Factor (BHLF)						Base Case Sensible Gain Factor (BSGF)					
R6 Insulation, ASHRAE Sealed (Supply = 0.12, Return = 0.24)						R6 Insulation, ASHRAE Sealed (Supply = 0.12, Return = 0.24)					
Square Feet of Floor Area						Square Feet of Ceiling Area					
OAT	1000	1500	2000	2500	3000	OAT	1000	1500	2000	2500	3000
-10	0.130	0.157	0.176	0.195	0.217	85	0.137	0.170	0.195	0.217	0.237
0	0.151	0.145	0.164	0.184	0.199	90	0.146	0.161	0.181	0.199	0.217
10	0.118	0.133	0.148	0.166	0.188	95	0.157	0.175	0.195	0.217	0.237
20	0.111	0.122	0.138	0.150	0.170	100	0.168	0.180	0.199	0.217	0.237
30	0.098	0.119	0.129	0.141	0.155	105	0.160	0.185	0.199	0.217	0.237
40	0.085	0.103	0.120	0.135	0.148						

R-Value Correction (WF - Heat Loss)	R2	R4	R6	R8
	2.02	1.28	1.00	0.84

R-Value Correction (WF - Sensible Gain)	R2
	2.19

Leakage Correction (LCF) for Heat Loss					Leakage Correction (LCF) for Sensible Gain				
Leakage	R2	R4	R6	R8	Leakage	R2	R4	R6	R8
0.06 / 0.06	0.87	0.83	0.78	0.75	0.06 / 0.06	0.87	0.85	0.81	0.81
0.09 / 0.15	0.92	0.89	0.86	0.85	0.09 / 0.15	0.95	0.92	0.89	0.89
0.12 / 0.24	1.00	1.00	1.00	1.00	0.12 / 0.24	1.00	1.00	1.00	1.00
0.24 / 0.47	1.40	1.56	1.68	1.81	0.24 / 0.47	1.29	1.35	1.40	1.40
0.35 / 0.70	1.84	2.21	2.47	2.75	0.35 / 0.70	1.56	1.74	1.81	1.81

**Default Duct Wall Surface Area (SqFt)**

Floor Area Look-Up Value									
1000 SqFt		1500 SqFt		2000 SqFt		2500 SqFt			
Supply	Return	Supply	Return	Supply	Return	Supply	Return		
189	5	276	7	361	9	431	11	461	12

See Sections 6-8 and 23-6 for instruction for determining the floor area look-up value.

**Surface Area Adjustment Factor (SAA) for Heat Loss or Sensible Gain**

SAA = K<sub>s</sub> x (Actual supply area / Default supply area) + K<sub>r</sub> x (Actual return area / Default return area)

Example: Floor area look-up value = 2,000 SqFt, duct leakage = 0.09 / 0.15, default areas = 361 and 9 SqFt. Actual system has 286 SqFt on supply side and 19 SqFt on return side.

- Combines these variables to generate a multiplier that is applied to the surface area.
- Ambient Temp
- R-value
- Leakage Rate
- Actual Surface Area
- This Multiplier x Envelope Load = Duct Load



## DUCT LEAKAGE

- Here's how Manual-J terminology lines up with duct testing standard of  $\text{cfm}_{25}/100$  sqft of conditioned floor area (based on trunk & branch system in attic – Table 7B-T)
  - Extreme = ~1.8%
  - Notable = ~3.3%
  - Average = ~4.7%
  - Partially = ~9.4%
  - Unsealed = ~13.8%



## INTERNAL LOADS

- # of people (230 sensible / 200 latent)
- Appliances
  - Kitchens are a must. Others are optional.
  - Some code officials require laundry room loads.
- Other loads
  - Plants
  - Electronics
  - Etc.



# INFILTRATION

Manual-J has ACH charts in 1000 sqft increments.  
Example of Single Story Residence - 2001-3000 sqft

Construction Quality	ACH Heating	ACH Cooling
Tight	.11	.06
Semi-Tight	.22	.11
Average	.32	.16
Semi-Loose	.49	.25
Loose	.66	.34

The most accurate method is based on blower door testing.  
Use target ACH50 from code to back into blower door #.



# VENTILATION

- Type
  - None
  - Outdoor Air
  - HRV (efficiency)
  - ERV (efficiency)
  - Ventilating Dehumidifier
- CFM
  - Base on ASHRAE 62.2





# WHERE TO FIND THE INFORMATION

Load Variable	Elite Load Reports	Wrightsoft Load Reports
Design Temps	Project Report Miscellaneous Report	Short Form Building Analysis Component Constructions Project Summary AED Assessment
Envelope Details	Total Building Summary Loads System Summary Loads	Component Constructions Right-J Worksheet
Orientation	Project Report – Frond Door Orientation Building Rotation General Overview Detailed Room Loads – Window Orientation	Multiple Orientations Report Component Constructions (Use window directions)
Ductwork Details Note that all duct characteristics do not show up on reports.	<b>Loads &amp; duct location show in:</b> Miscellaneous Report	<b>Loads show in:</b> Building Analysis Project Summary Right-J Worksheet
Infiltration	Miscellaneous Report Total Building Summary Loads System Summary Loads	Building Analysis Component Constructions Project Summary
Ventilation Note that type & efficiency does not show up on reports.	Miscellaneous Report Total Building Summary Loads System Summary Loads	<b>Loads show in:</b> Load Short Form ("Other Equip. Loads") Building Analysis Project Summary
Appliance Loads	Total Building Summary Loads System Summary Loads	Right-J Worksheet

# WHERE TO FIND THE INFORMATION

	Elite Load Reports	Wrightsoft Load Reports
Reports to Request	Project Report Total Building Summary Loads Miscellaneous Report	Component Constructions Project Summary Right-J Worksheet



# DESIGN TEMPS

Rhvac - Residential & Light Commercial HVAC Loads				Elite Software Development, Inc.		
Calico Plus North Venice, FL 34275				Mr. & Mrs. Smith Page 2		
<b>Design Data</b>						
Reference City:	Sarasota, Florida					
Building Orientation:	Front door faces South					
Daily Temperature Range:	Medium					
Latitude:	27 Degrees					
Elevation:	26 ft.					
Altitude Factor:	0.999					
Elevation Sensible Adj. Factor:	1.000					
Elevation Total Adj. Factor:	1.000					
Elevation Heating Adj. Factor:	1.000					
Elevation Heating Adj. Factor:	1.000					
	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	42	39.4	80%	n/a	70	n/a
Summer:	92	77	51%	50%	75	51
<b>Design Conditions</b>						
Location:	Example City, XX					
Elevation:	77 ft					
Latitude:	33°N					
Indoor:	Indoor temperature (°F)					
	Heating 70					
	Cooling 75					
	Design TD (°F)					
	Heating 68					
	Cooling 64					
	Relative humidity (%)					
	Heating 30					
	Cooling 50					
	Moisture difference (gr/lb)					
	Heating 30.6					
	Cooling 40.3					
Outdoor:	Dry bulb (°F)					
	Heating -13					
	Cooling 99					
	Wetbulb (°F)					
	Heating 70					
	Cooling 77					
	Wind speed (mph)					
	Heating 15.0					
	Cooling 7.5					
Infiltration:	Method					
	Simplified					
	Average					
	Construction quality					
	1 (Tight)					
	Fireplaces					



# ENVELOPE DETAILS

Component Description	Area Quan
1A-cb-o: Glazing-Single pane, operable window, clear, metal frame with break, outdoor insect screen with 50% coverage, white or reflective color drapes with tight weave with 50% coverage, u-value 1.08, SHGC 0.75	115.4
1A-cb-d: Glazing-Single pane, sliding glass door, clear, metal frame with break, outdoor insect screen with 100% coverage, u-value 1.08, SHGC 0.75	80.4

Construction descriptions	Or	Area ft²	U-value Btu/ft²·°F	Insul R ft²·h/Btu	Htg HTM Btu/ft²	Loss Btu/h	Cig HTM Btu/ft²	Gain Btu/h
<b>Walls</b>								
12E-0sw: Frm wall, wd ext, 1/2" wood shth, r-19 cav ins, 1/2" gypsum board int fsh, 2"x6" wood frm	n	184	0.068	19.0	5.64	1038	2.14	393
	e	275	0.068	19.0	5.64	1550	2.14	586
	s	214	0.068	19.0	5.64	1208	2.14	457
	w	221	0.068	19.0	5.64	1245	2.14	471
	all	893	0.068	19.0	5.64	5042	2.14	1907



# ORIENTATIONS

## Design Data

Reference City: Sarasota, Florida  
 Building Orientation: Front door faces Southwest  
 Daily Temperature Range: Medium  
 Latitude: 27 Degrees  
 Elevation: 26 ft.  
 Altitude Factor: 0.999

	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	42	39.4	n/a	n/a	70	n/a
Summer:	92	77	51%	45%	75	58

	North	Northeast	East	Southeast	South	Southwest	West	Northwest
Sensible Load (Btuh)	12735	13206	11484	12846	11154	11581	11449	12964
Latent Load (Btuh)	2543	2591	2525	2543	2517	2525	2523	2586
Total Load (Btuh)	15278	15797	14009	15389	13671	14107	13972	15549
Heating AVF (cfm)	542	564	488	547	473	492	486	554
Cooling AVF (cfm)	542	564	488	547	473	492	486	554



# DUCTWORK


Component Description	Area Quan	Sen Loss	Lat Gain	Sen Gain	Total Gain
Ductwork:		4,747	569	4,899	5,468

## Duct Load Factor Scenarios for System 1

No.	Type	Description	Location	Attic Ceiling	Duct Leakage	Duct Insulation	Surface Area	From [T]MDD
1	Supply		Closed Crawl A	-	0.12	8	189	No
1	Return		Closed Crawl A	-	0.24	8	35	No

## Cooling

Component	Btuh/ft <sup>2</sup>	Btuh	% of load
Walls	2.1	1907	13.4
Glazing	24.2	4009	28.1
Doors	14.2	298	2.1
Ceilings	1.7	1171	8.2
Floors	0.9	649	4.5
Infiltration	0.9	988	6.9
Ducts		3021	21.2
Ventilation		579	4.1
Internal gains		1660	11.6
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>14283</b>	<b>100.0</b>



# INPUTS FOR DUCTS (not all data is in reports)

**Duct Loads for Room1**

**Supply**

Location: Conditioned space

Roof material: Asphalt shingle  
 Tar and gravel  
 Metal or membrane  
 Wood shake  
 Tile, slate, or concrete

Roof color: Dark  
 Light  
 White

Configuration: Radial, perimeter outlets

Sealing: Average Insul.R: 6.0 R-F/Btuh

Heating discharge air temperature: 100 °F

Ambient temperature: Heat (70) °F Surface area (14.5) ft²  
 Cool (75) °F

**Return**

Location: Conditioned space

Roof material: Asphalt shingle  
 Tar and gravel  
 Metal or membrane  
 Wood shake  
 Tile, slate, or concrete

Roof color: Dark  
 Light  
 White

Configuration: Radial

Sealing: Average Insul.R: 6.0 R-F/Btuh

Ambient temperature: Heat (70) °F Surface area (10.5) ft²  
 Cool (75) °F

**Results:**

Description: Supply: Conditioned space, radial, perimeter outlets, average sealing, R-6  
 Return: Conditioned space, radial, average sealing, R-6

Heat loss: (0.0) % Sensible gain: (0.0) % Latent gain: (0) Btuh

**System 1 Duct Load Factors - Scenario 1 of 5**

**System 1 Duct Properties**

Supply Return

Duct Location: Attic Attic

Attic Ceiling Type: 16B 16B

Duct Leakage Rate: 0.06 0.06

Duct Insulation R-Value: 6 6

Duct Surface Area: 369 137

Update SA from [T]MDD: No No

**Results**

	System 1 Duct Load	Percent of Total Load	Manual Override
Sensible Loss:	4,704	18	<input type="checkbox"/>
Sensible Gain:	4,166	17	<input type="checkbox"/>
Latent Gain:	591	22	<input type="checkbox"/>

**Multiple Duct Scenarios (Optional)**

If the ducts in this system are in more than one location or have other properties that differ, you can change the Duct Scenario Number below and enter "Duct Properties" data for additional scenarios (up to 5 total).

Duct Scenario No.: 1 Desc.: Main

Total Duct Surface Area for System 1: Supply 369 Return 137

Scenario 1 Percentage: 100% 100%



# INFILTRATION

	Winter	Summer
Infiltration Specified:	0.310 AC/hr 65 CFM	0.160 AC/hr 33 CFM
Infiltration Actual:	0.310 AC/hr	0.160 AC/hr
Above Grade Volume:	X 12,535 Cu.ft. 3,886 Cu.ft./hr X 0.0167	X 12,535 Cu.ft. 2,006 Cu.ft./hr X 0.0167
Total Building Infiltration:	65 CFM	33 CFM


Design Conditions			
<b>Location:</b> Example City, XX Elevation: 77 ft Latitude: 33°N		<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 83 30 30.6
<b>Outdoor:</b> Drybulb (°F) Daily range (°F) Wetbulb (°F) Wind speed (mph)	<b>Heating</b> -13 - - 15.0	<b>Cooling</b> 99 10 ( L ) 77 7.5	<b>Cooling</b> 75 24 50 40.3
		<b>Infiltration:</b> Method Construction quality Fireplaces	Simplified Average 1 (Tight)



# VENTILATION

Infiltration: Winter CFM: 65, Summer CFM: 33  
 Ventilation: Winter CFM: 0, Summer CFM: 0

1,993 1,166 625 1,791  
 0 0 0 0



# INPUTS FOR VENTILATION (not in reports)

- Outdoor Air
  - Via Location
- HRV/ERV
  - Efficiency
- Dehumidifier
  - Dry bulb temp
  - Humidity Ratio

**Infiltration:** 0 0

**Ventilation:** 0 0

**Exhaust:** 0 0

**Do Heat Recovery:** No No

**Heat Recovery SER:** 60 60

Central Vent System Details for Entire House

Type: Heating: Ventilating dehumidifier Cooling: Ventilating dehumidifier

Recovery effectiveness

Sensible (SER) 50 % 0 %

Latent (LER) 50 % 0 %

Leaving air state

Dry bulb temperature 19 °F 101 °F

Humidity ratio 12.2 gr/lb 84.7 gr/lb

Help OK Cancel



# APPLIANCES & PEOPLE

Component Description	Area Quan	Sen Loss	Lat Gain	Sen Gain	Total Gain
People:	4		800	920	1,720
Equipment:			1,200	1,200	2,400
Lighting:	0			0	0

1 2 3 4 5	Room name Exposed wall Room height Room dimensions Room area	Dining 12.0 ft 10.0 ft x 12.0 ft x 13.5 ft 162.0 ft²						Kitchen 23.5 ft 10.0 ft x 10.0 ft x 13.5 ft 135.0 ft²							
		U-value (Btu/ft²·°F)		Or HTM (Btu/ft²)		Area (ft²) or perimeter (ft)		Load (Btu/h)		Area (ft²) or perimeter (ft)		Load (Btu/h)			
Ty		Construction number		Heat		Cool		Gross		N/P/S		Heat		Cool	
13	Internal gains: Occupants @ Appliances/other	230		0				0		1				230 1200	



# BUILDING LOAD RESULTS

Building Loads	
Total Heating Required Including Ventilation Air:	26,307 Btuh 26.307 MBH
Total Sensible Gain:	19,568 Btuh 84 %
Total Latent Gain:	3,735 Btuh 16 %
Total Cooling Required Including Ventilation Air:	23,303 Btuh 1.94 Tons (Based On Sensible + Latent)

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Entire House	704	25599	13704	587	587
Other equip loads		2003	579		
Equip. @ 1.04 RSM			14854		
Latent cooling			2596		
TOTALS	704	27602	17450	587	587



## ENCAPSULATED ATTICS (Wrightsoft)


Construction descriptions	Or	Area ft <sup>2</sup>	U-value Btu/h/ft <sup>2</sup> ·°F	Insul R ft <sup>2</sup> ·°F/Btu/h	Htg HTM Btu/h/ft <sup>2</sup>	Loss Btu/h	Clg HTM Btu/h/ft <sup>2</sup>	Gain Btu/h
<b>Ceilings</b> 16X19-0md: Attic ceiling, mtl roof mat, r-20 roof ins, 1/2" gypsum board int fnsh		704	0.408	19.0	4.70	3308	2.11	1488

- This is indicating the U-value of a ceiling below an encapsulated attic. The Clg HTM represents an attic temp of 85°.
- As the R-value of foam changes, the HTM's will change, but the U-value will not.



## MANUAL-S

- Provides a process of properly selecting equipment
- Currently being re-written by ACCA



## MANUAL-S SELECTION BASICS

- Heating Only Systems
  - Pick a unit that will meet the heating load.
  - 140% max for furnaces
- Air Conditioner or Heat Pump
  - Select based on cooling capacity
  - Max 115% (125% in cold climates)
  - **Both** the **sensible** and **latent** loads must be satisfied by the selected equipment.



## PROCESS OVERVIEW

- Determine sensible & latent loads of house
- Divide total load by 12,000 to get you started
- Look up “detailed capacity chart” of condenser and find the size that you believe may satisfy the load.
- Interpolate capacity data based on your outdoor/indoor conditions and the altitude.
- Ensure it doesn't exceed the Manual-S sizing limits.





# REQUIRED DATA SUMMARY

- Manual-J Loads (reports)
- Outdoor Design Conditions (City, State)
- Indoor Cooling Design Conditions (75/50)
- Estimated CFM for Cooling




# DETAILED COOLING CAPACITIES

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES c										
CFM	EWB	75			85			95		105		
		Capacity MBtu/h†		Total Sys-tem KW* *	Capacity MBtu/h†		Total Sys-tem KW* *	Capacity MBtu/h†		Capacity MBtu/h†		
		Total	Sens ‡		Total	Sens ‡		Total	Sens ‡	Total	Sens ‡	
<b>25HPA524.30 Outdoor Section With FX4C VF030 Indoor Section</b>												
700	72	28.21	14.49	1.47	26.92	13.99	1.65	25.57	13.46	1.85	24.13	12.92
	67	25.60	17.78	1.46	24.41	17.26	1.64	23.15	16.72	1.84	21.81	16.16
	63	23.74	17.18	1.46	22.61	16.65	1.64	21.42	16.11	1.84	20.16	15.53
	62	23.27	21.07	1.46	22.17	20.52	1.64	21.02	19.95	1.84	19.80	19.32
800	57	22.41	22.41	1.46	21.53	21.53	1.64	20.61	20.61	1.83	19.62	19.62
	72	28.81	15.19	1.49	27.47	14.68	1.67	26.06	14.14	1.87	24.57	13.59
	67	26.16	18.90	1.49	24.91	18.37	1.67	23.60	17.82	1.87	22.21	17.25
	63	24.26	18.23	1.48	23.08	17.69	1.66	21.84	17.14	1.86	20.53	16.55
850	62	23.82	22.56	1.48	22.69	21.98	1.66	21.53	21.32	1.86	20.39	20.39
	57	23.35	23.35	1.48	22.42	22.42	1.66	21.44	21.44	1.86	20.39	20.39
	72	28.81	15.19	1.49	27.47	14.68	1.67	26.06	14.14	1.87	24.57	13.59

$23.60 - 17.82 = 5.78 \rightarrow \text{Latent Capacity} = 5,780 \text{ btu's}$

Remember to deduct sensible capacity if EDB < 80°  
835 btu/1000cfm/degree in this case

28  
52  
05  
05



## COOLING CAPACITY FOOTNOTES

- Often times, these charts are based on a fixed EDB temp. In the previous chart, for instance, it was 80°F.
- If your EDB temp is different, you need to adjust the capacities listed in these charts.
  - Sometimes, another chart will provide multipliers.
  - Sometimes, it will give you a BTU/degree adjustment figure (add or subtract as needed).
- READ THE FOOTNOTES !!!!!!!!!!!



# EXAMPLE PROJECT



- One system down, Furnace with A/C
- One system up, Heat pump



# INTRODUCTION TO THE SPEEDSHEET

**Equipment Selection Analysis via Manual-S Protocols**

Completed: Tom Conroy Home  
Phone: 423-454-7858

Project Information		Billing Information	
Name:	John Doe	Address:	123 Main St, Nashville, TN
Address:	123 Main St, Nashville, TN	City:	Nashville, TN
City:	Nashville, TN	State:	TN
Zip:	37203	Phone:	615-555-1234
Project:	REPLACEMENT	Project Start:	08/20/2023

System	Manufacturer	Model	Capacity	SEER	AFUE	Notes
Furnace	Carrier	58	30	13	80	Existing
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
A/C	Carrier	58	30	13	80	Existing
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed

System	Manufacturer	Model	Capacity	SEER	AFUE	Notes
Heat Pump	Carrier	58	30	13	80	Existing
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed

System	Manufacturer	Model	Capacity	SEER	AFUE	Notes
Water Heater	Carrier	58	30	13	80	Existing
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed

System	Manufacturer	Model	Capacity	SEER	AFUE	Notes
Sizing Capacity at Better Conditions	Carrier	58	30	13	80	Existing
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed
	Carrier	58	30	13	80	Proposed



# INTRODUCTION TO THE SPEEDSHEET

Out DB per Chart	85	CFM	Return Air (F wb)	Total BTUH	Sensible BTUH	Latent BTUH	SHR
In DB per Chart	80						
Capacity from MFG table							#DIV/0!
Modified for Design DB							#DIV/0!
Capacity from MFG table			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Modified for Design DB							#DIV/0!
Capacity from MFG table							#DIV/0!
Modified for Design DB							#DIV/0!
Output from this chart			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

Out DB per Chart	85	CFM	Return Air (F wb)	Total BTUH	Sensible BTUH	Latent BTUH	SHR
In DB per Chart	80						
Capacity from MFG table							#DIV/0!
Modified for Design DB							#DIV/0!
Capacity from MFG table			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Modified for Design DB							#DIV/0!
Capacity from MFG table							#DIV/0!
Modified for Design DB							#DIV/0!
Output from this chart			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

Out DB	85	CFM	Return Air (F wb)	Total BTUH	Sensible BTUH	Latent BTUH	SHR
In DB	70						
Interpolated Equipment Capacity							#DIV/0!
Excess Latent Capacity Calculation			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Capacity @ Design Conditions							#DIV/0!
Equipment Capacity as a % of Design				#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
COOLING CAPACITY AT DESIGN CONDITIONS		CFM	Return Air WB	Total Capacity	Sensible	Latent	SHR
			63	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!



## Questions & Answers

Isaac Savage, CEM  
 Training Development Director  
 Training@HomeEnergyPartners.com

