

HERS BESTEST results for:

Software Name: EnergyGauge USA 2.5

User input data fields indicated by pale yellow  
Test result fields indicated by pale green

Annual Loads

Heating	range max	range min	Result	pass/fail
L100AC	79.48	48.75	58.64	pass
L110AC	103.99	71.88	80.01	pass
L120AC	64.30	37.82	43.91	pass
L130AC	53.98	41.82	45.63	pass
L140AC	56.48	42.24	47.52	pass
L150AC	71.33	40.95	49.90	pass
L155AC	74.18	43.53	52.28	pass
L160AC	81.00	48.78	57.90	pass
L170AC	92.40	61.03	68.81	pass
L200AC	185.87	106.41	135.88	pass
L202AC	190.05	111.32	145.49	pass
L302AC	86.90	56.12	60.59	pass
L304AC	73.15	46.11	52.48	pass
L322AC	111.69	73.71	77.90	pass
L324AC	77.47	46.38	54.69	pass

Annual Load deltas

Heating	range max	range min	Result	pass/fail
L110-L100	28.12	19.36	21.37	pass
L120-L100	-7.67	-18.57	-14.73	pass
L130-L100	-5.97	-27.50	-13.01	pass
L140-L100	-4.56	-24.42	-11.12	pass
L150-L100	-3.02	-12.53	-8.74	pass
L155-L150	6.88	-1.54	2.38	pass
L160-L100	5.10	-3.72	-0.74	pass
L170-L100	17.64	7.12	10.17	pass
L200-L100	107.66	56.39	77.24	pass
L202-L200	9.94	-0.51	9.61	pass
L302-L100	14.50	-3.29	1.95	pass
L302-L304	17.75	5.66	8.11	pass
L322-L100	39.29	15.71	19.26	pass
L322-L324	38.22	21.25	23.21	pass

Cooling	range max	range min	Result	pass/fail
L100AL	64.88	50.66	53.21	pass
L110AL	68.50	53.70	56.17	pass
L120AL	60.14	47.34	47.54	pass
L130AL	45.26	32.95	38.39	pass
L140AL	30.54	19.52	25.82	pass
L150AL	82.33	62.41	66.82	pass
L155AL	63.06	50.08	54.29	pass
L160AL	72.99	58.61	62.82	pass
L170AL	53.31	41.83	43.32	pass
L200AL	83.43	60.25	66.97	pass
L202AL	75.96	52.32	53.16	pass

Cooling	range max	range min	Result	pass/fail
L110-L100	7.84	-0.98	2.96	pass
L120-L100	0.68	-8.87	-5.67	pass
L130-L100	-13.71	-24.40	-14.82	pass
L140-L100	-27.14	-38.68	-27.39	pass
L150-L100	20.55	8.72	13.61	pass
L155-L150	-9.64	-22.29	-12.53	pass
L160-L100	12.28	3.88	9.61	pass
L170-L100	-4.83	-15.74	-9.89	pass
L200-L100	21.39	6.63	13.76	pass
L200-L202	14.86	2.03	13.81	pass