

DSE Test Suite Results**Software Name:** EnergyGauge USA 2.5

User input data fields indicated by pale yellow

Test result fields indicated by pale green

Results:

Base Cases	Heat/cool	Fan	Total	% change	
HVAC-3a	714	555	73.29	---	base for cases 3b - 3d
HVAC-3e	5697	1053	6750	---	base for cases 3f - 3h

Criteria:

Test Cases	Heat/cool	Fan	Total	% change	max	avg	min	Pass/Fail
HVAC-3b	916	556	93.50	27.6%	31.4%	26.4%	21.4%	pass
HVAC-3c	762	556	78.10	6.6%	12.5%	7.5%	2.5%	pass
HVAC-3d	838	591	85.82	17.1%	25.0%	20.0%	15.0%	pass
HVAC-3f	7437	1385	8822	30.7%	36.2%	31.2%	26.2%	pass
HVAC-3g	6187	1144	7331	8.6%	16.5%	11.5%	6.5%	pass
HVAC-3h	7436	1361	8797	30.3%	31.1%	26.1%	21.1%	pass