

DSE Test Suite Results

Software Name: MICROPAS7

User input data fields indicated by pale yellow
 Test result fields indicated by pale green

Results:

Base Cases	Heat/cool	Fan	Total	% change	
HVAC-3a	863.6868	336.6891	87.52	---	base for cases 3b - 3d
HVAC-3e	25.74563	*Included	25.74563	---	base for cases 3f - 3h

Test Cases	Heat/cool	Fan	Total	% change	Criteria:			Pass/Fail
					max	avg	min	
HVAC-3b	1134.397	441.9045	114.95	31.3%	31.4%	26.4%	21.4%	pass
HVAC-3c	961.2594	374.266	97.40	11.3%	12.5%	7.5%	2.5%	pass
HVAC-3d	1035.593	402.8245	104.93	19.9%	25.0%	20.0%	15.0%	pass
HVAC-3f	34.11319	*Included	34.11319	32.5%	36.2%	31.2%	26.2%	pass
HVAC-3g	27.81991	*Included	27.81991	8.1%	16.5%	11.5%	6.5%	pass
HVAC-3h	31.94203	*Included	31.94203	24.1%	31.1%	26.1%	21.1%	pass

