

DSE Test Suite Results

Software Name: REM/Rate v12.11

User input data fields indicated by pale yellow
 Test result fields indicated by pale green

Results:

| Base Cases | Heat/cool | Fan | Total | % change | |
|------------|-----------|-----|-------|----------|------------------------|
| HVAC-3a | 74.5 | | 7.45 | --- | base for cases 3b - 3d |
| HVAC-3e | 22.8 | | 22.8 | --- | base for cases 3f - 3h |

| Test Cases | Heat/cool | Fan | Total | % change | Criteria: | | | Pass/Fail |
|------------|-----------|-----|-------|----------|-----------|-------|-------|-----------|
| | | | | | max | avg | min | |
| HVAC-3b | 91 | | 9.10 | 22.1% | 31.4% | 26.4% | 21.4% | pass |
| HVAC-3c | 78.4 | | 7.84 | 5.2% | 12.5% | 7.5% | 2.5% | pass |
| HVAC-3d | 87.8 | | 8.78 | 17.9% | 25.0% | 20.0% | 15.0% | pass |
| HVAC-3f | 28.8 | | 28.8 | 26.3% | 36.2% | 31.2% | 26.2% | pass |
| HVAC-3g | 24.6 | | 24.6 | 7.9% | 16.5% | 11.5% | 6.5% | pass |
| HVAC-3h | 27.7 | | 27.7 | 21.5% | 31.1% | 26.1% | 21.1% | pass |