

RESNET HVAC Test Suite Results:

Software Name: EnergyGauge USA 2.5

User input data fields indicated by pale yellow

Test result fields indicated by pale green

Results

Cooling tests:

Case	Cool	Cool Fan	Cool Tot	% change	Criteria		
					min	max	
HVAC-1a	5813	1064	6877	---			
HVAC-1b	4470	1064	5534	-19.53%	-21.24%	-17.38%	pass

Heating tests:

Case	Heat	Heat Fan	Heat Tot	% change	Criteria		
					min	max	
HVAC-2a	749	583	76.89	---			
HVAC-2b	650	583	66.99	-12.88%	-13.30%	-11.57%	pass
HVAC-2c	8226	1330	9556	---			
HVAC-2d	6023	1018	7041	-26.32%	-29.03%	-16.73%	pass
HVAC-2e	15990	875	16865	76.49%	41.81%	80.81%	pass