

**Results**

Cooling tests:

Case	Cool	Cool Fan	Cool Tot	% change
HVAC-1a	23.7		23.7	---
HVAC-1b	19.3		19.3	-18.57%

Criteria

min                  max

-21.24%    -17.38%    pass

Heating tests:

Case	Heat	Heat Fan	Heat Tot	% change
HVAC-2a	89.4		8.94	---
HVAC-2b	77.8		7.78	-12.98%

-13.30%    -11.57%    pass

Case	Heat	Heat Fan	Heat Tot	% change
HVAC-2c	47.4		47.4	---
HVAC-2d	37		37	-22.15%
HVAC-2e	70.3		70.3	48.31%

-29.03%    -16.73%    pass  
41.81%    80.81%    pass