

Measuring Air Leakage in High Rise Buildings

Denali Jones
Retrotec Energy Ltd






Contents

- Cause
- Problems
- Sites
- Benefits
- Ventilation
- Air barriers
- Locate and seal leaks
- Measure leaks
- Case Studies




Cause of air leakage

Stack Pressure + Holes = Leaks



Primary Boundaries for cold climates



14 windows open at -25 C

inset shows open window





Why air tightness is important?



Airtightness defines a building



Impact on energy cost


CFM 75/ft ²		
0.1	0%	Negligible
0.25	5%	Small
0.4	10%	Moderate
1.0	25%	Large
2.0	40%	Uncontrolled, severe

7x more exposure in a house = more energy per person




© 2010 Retrotec Inc.

Real problems





Typical Leaky High-Rise Buildings:



CONCENTRATED
CONDENSATION

VAPOR
BARRIER






Cool wall
temperatures
causes mold



Smoke safety is affected by floor to floor leakage




Hallway mechanicals cannot keep up with flow requirements



Reduce noise from outdoors




Reduced entry of hot humid air




Disconnect Floors



Seal shafts



Improved Air tightness in Elevator Shafts



To determine pass/fail for new construction

“shall pass ...0.25 CFM/sq ft ...at 75 Pa ...”

=1.0 liters/s @ 50 Pa /m²



**US Army Corps
of Engineers®**
Engineer Research and
Development Center

Standards for air leakage – pass/fail



**US Army Corps
of Engineers®**




Required House tightness?

Standard	Requirement	CFM75/ ft ²
LEED	1.25 in ² EfLA @ 4 Pa / 100 ft ²	0.30
2009 IECC	7.0 ACH50	0.55
2012 IECC	3.0 ACH50	0.25
Cdn R-2000	1.5 ACH50	0.13
Passiv Haus	0.6 ACH50	0.05





Large Bldg tightness?

4 story building, 120 x 110 x 40 ft, n= 0.65			CFM75 / ft ²
USA	ASHRAE 90.1 Leaky		0.60
France		1.2 m ³ /m ³ /h @4Pa /m ²	0.44
USA	IECC, Washington State		0.40
Russia		1.5 l/s @50Pa /m ²	0.385
UK	TS-1Commercial, Best	5 m ³ /h @50Pa /m ²	0.36
USA	ASHRAE 90.1 Average		0.30
USA	USACE, IGCC		0.25
UK	TS-1Commercial Tight	2 m ³ /m ³ /h @50Pa /m ²	0.14
USA	ASHRAE 90.1 Tight		0.10



Air leakage is measured to determine weatherization effectiveness



Dual Channel Digital Micromanometer and Control

	Baseline	Δ	Time	Zero
	0.11 Pa	---- 0.65	2s	On
Pressure	PrA	75.0 Pa		
Mode	Flow /Area	1.200 cfm/ft ² @75.0Pa		
	area :	1000.0 ft ²		
Set				Speed Device
Range Config	B		Retrotec 2000	

DM-2 mark II

Dual Channel Digital Micromanometer and Control

	Baseline	Δ	Time	Zero
	0.11 Pa	---- 0.65	2s	On
Pressure	PrA	75.0 Pa		
Mode	Flow /Area	0.200 cfm /ft ²		
	area :	1000.0 ft ²		
Set				Speed Device
Range Config	B		Retrotec 2000	

DM-2 mark II

Air leakage is measured to run predictive models

ASTM 2010-06-04 1751.xml - Retrotec FanTestic (5.1.8)
File View Sets Tools Help

Infiltration Effects Climate location Climate Data Heat

# of stories	<input type="text"/>	Heating cost	<input type="text"/> /kwh	<input type="text"/> %	Winter: design
Bedrooms	<input type="text"/>	Cooling cost	<input type="text"/> \$/kwh	<input type="text"/> S	Summer: design
Occupants	<input type="text"/>	Shelter class	<input type="text" value="Select shelter..."/>	ation c	Heat

Automatic save of 'ASTM 2010-06-04 1751.xml' completed at 2010-08-31 13:17.

CONTAMW2 - HOUSE.prj _ □ ×

File Edit View Level Tools Data Weather Simulation Help

Zone: Ambt Col 1, Row 1 Level grnd: 2 of 4


Recommendations

- Assemblies-0.01 cfm /ft² @75
- Walls 0.1 cfm /ft² @75
- Slabs 0.01 cfm /ft² @75
- Paint all block walls
- Seal all shafts at each floor
- Enclose elevator lobbies from slab to slab
- Electronic exhaust fan & fire dampers



Locate and seal leaks


Locate leaks with door fan using smoke, infrared, hand




Door fan finds leaks



Door fans and infrared camera




Exterior wall leaks









Smoke Testing Used to Confirm Air Barrier Discontinuity






Smoke and IR identify air leakage paths













Sealing air leaks


Steel deck to masonry wall:



Roof penetrations:



Can lights:



Access hatches:







Measure leaks

Door-Fan components panel + calibrated fan + gauges



Rigger



Seal these



Open interior doors




Setting up the test fans






What components of buildings can be measured?

Whole building envelopes can be measured



Individual apartments can be measured



Hallways can be measured






Stairwells can be measured




Floor to floor leakage can be measured




Total Unit Leakage - All 6 Sides, 1 Door Fan


1 system




Side View



Top Down View




Measure Entire Envelope




Total Unit Leakage - All 6 Sides, 1 Door Fan

1 system




Side View




Top Down View

Leakage from Apartment to Hallway




Side View




Top Down View

Leakage across 1st Party Wall




Side View




Top Down View

Leakage across 2nd Party Wall




Side View




Top Down View

Pressurizing the Floor Above





Side View



Top Down View

Floor to floor leakage can be measured



Elevator shafts can be measured



Case Studies



Air leakage Test Protocol for U.S. Army Corps Buildings



Requirements

- Proper design
- Plan review
- Ongoing inspection
- Mock up building materials
- Pass air leakage protocol
 - easy
 - not just the ASTM E779 standard



CERTIFICATE

Guinness World Record 15,000,000 cubic feet








Hallenumfang = 1,2 km





9 x 2
Refer

Real life test: EMAD

Antwerp, Belgium


- Envelope Area = 11,250 m²
- 0.601 CFM/ft² @ 75Pa
- 8.22 m³/h/m²



Real life test: BTC

South Carolina, USA

- Envelope A = 136,820ft²
- 0.08 CFM/ft² @ 75Pa



Real life test: Retrotec Vancouver, Canada

- Envelope Area = 25,000 ft²
- 0.4 CFM/ft² @ 75Pa
- 7.3 m³/h/m²



Building Air Leakage Test

In compliance with European Norm EN13829

Retrotec FanTestic, version 0.9.62 License# Free Beta Version



Test technician: **Tim Lochner**

#1 Door Fan Model: **Retrotec DU200** S/N: **0** Gauge Model: **DM-2** S/N: **201653**

Building Address: **1639 West 2nd Ave - Unit 330 Vancouver, BC Canada V6J1H3**

Elevation: **0** m Volume, V: **500** m³

Height of Building above ground: **20** m Total envelope area, AT: **480** m²

Building exposure to wind: **A: Highly protected build** Floor area, AF: **120** m²

Accuracy of building measurements: **5** %

Start date: **2010-1-21** Start time: **09:37** **Depressurization set**

Barometric press: **101** kPa from **Stand. temp. and pressure** Wind speed (Beaufort): **0: Calm** Operator loc: **Inside**

Take **12** bias pressures for **10** sec each. Take **12** building pressures from **15** to **70** Temperature indoors **20** °C outdoors **20** °C

Start Autotest **Show Graphs**

Bias pressure, initial [Pa]	.02	-.109	-.033	.025	-.164	-.112	-.103	-.143	-.11	.018	-.131	-.066
Bias Average Δf	-0.076											
ΔP _{in}	-0.108											
ΔP _{in} +	0.021											
Building gauge pressure [Pa]	-15.2	-20.9	-25.7	-30.4	-35.8	-40.1	-45.3	-49.9	-55.1	-59.7	-64.8	-69.4
Door Fan 1 Range Low	113.1	153.6	187.5	217.2	253.8	284.5	319.1	351.9	391.8	425	461.6	496.2
Door Fan 1 Range	113.1	153.6	187.5	217.2	253.8	284.5	319.1	351.9	391.8	425	461.6	496.2
Bias pressure, final [Pa]	-.694	-.099	-.118	-.032	-.374	-.413		-.03	-.159	-.13	-.136	.012
Bias ΔP _{in}	-0.181											
ΔP _{in}	-0.219											
ΔP _{in} +	0.006											
Temperature indoors	20											
Temperature outdoors	20											
Total flow, V _r [m ³ /h]	30.3	36.3	40.7	44.2	48.3	51.4	54.8	57.8	61.2	63.8	66.6	69.1
Corrected flow rate, V _{env} [m ³ /h]	30	36	41	44	48	52	55	58	61	64	67	69
Error [%]	-0.42%	0.34%	0.57%	-0.14%	-0.15%	-0.06%	-0.21%	-0.19%	0.19%	0.14%	-0.05%	-0.02%

Correlation, r [%] **100.0** Confidence Limit

Intercept, Cerv [m ³ /h, Pa ⁿ]	7.1	7.0	7.2
Intercept, CL [m ³ /h, Pa ⁿ]	7.1	7.0	7.2
Slope, n	0.537	0.533	0.541

Calculate

Clear data

Delete set

New set

Results Uncertainty






Air flow at 50 Pa, V ₅₀ [m ³ /h]	58	+/-10%
Air changes at 50 Pa, n ₅₀ [/h]	.12	+/-11%
Air flow at 4 Pa, V ₄ [m ³ /h]	15	+/-10%
Permeability at 4 Pa, Q _s [m ³ /h.m ²]	.03	+/-11%
Effective leakage area at 4 Pa, AL [cm ²]	16	+/-10%

Finish time: **09:59**

(add notes here)

Warnings and Errors

1 DM2 gauge found. Gauge #201653 on Retrotec DU200, Range Low.



Start Test Stop Test Change Range Clear data

Auto test completed.

Cover fans before taking bias readings? Yes No

Previous step:

Step 2: Flow pressure at 12 points, -15 Pa, -20 Pa, -25 Pa, -30 Pa, -35 Pa, -40 Pa, -45 Pa, -50 Pa, -55 Pa, -60 Pa, -65 Pa, -70 Pa, each point collected for 20 seconds (minimum 20 readings).

Current step:

Step 3: Bias Pressure. 12 points, averaged from data collected over 10 seconds (minimum 10 readings)


Next step:

1 DM2 gauge found. Gauge #201653 on Retrotec DU200, Range Low. Gauges ready. Click start when read to start autotest.




Imbalanced flow can be caused by individual set points.

3. Multiple Zones - Leaky:



*Use a USB hub if computer does not have enough USB ports

Individual set point *between* zones Common set point *within* a zone.





*Use a USB hub if computer does not have enough USB ports

2012 Model Drives Setup

(Individual set point)

Connections that work best:





Automatic vs. manual data collection

Start date		2010-06-02		Start time		19:37		Get Time		Pressurization set										
Average wind speed		8 mph		Direction		WN		Operator location		Inside		Temperature, initial		indoors 75 °F		outdoors 87 °F				
Start Auto-Test		Show Graphs																		
Bias pressure, initial [Pa]				.727	1.093	1.227	.649	.81	1.129	1.223	.881	.843	1.284	.971	1.011					
											Greatest Initial Bias Pressure		1.284 Pa		Time per Bias Pressure		10 sec.			
#1 Building (gauge) pressure [Pa]				25.1	28.9	33.9	38.0	43.0	47.0	52.0	55.6	60.9	65.0	69.9	75.1					
#2 Building pressure variation [%]				2.1%	2.4%	2.3%	2%	1.9%	2.1%	2.3%	2.1%	-.3%	%	.1%	-.1%					
#3 Building pressure variation [%]				3%	3.1%	3.3%	3%	2.8%	3%	2.9%	2.8%	1.4%	1.5%	1.2%	1.3%					
#4 Building pressure variation [%]				2.6%	2.5%	2.7%	2.1%	1.7%	2.1%	2.2%	1.8%	1.8%	2%	1.8%	1.7%					
#5 Building pressure variation [%]				-1.4%	-1.1%	-.7%	-.8%	-.9%	-.8%	-.7%	-.1%	-.3%	-2.7%	-3.1%	-3%					
#6 Building pressure variation [%]				-.5%	-.5%	-.2%	-.1%	-.1%	-.1%	-.1%	-.1%	-2.8%	-2.3%	-2.6%	-2.8%					
Door Fan 1		A		[Pa]																
Door Fan 1				88.9	109.2	131.2	152.7	167.6	189.8	212.8	237.0									
Door Fan 2		A		[Pa]																
Door Fan 2				75.9	93.6	116.9	136.8	160.7	181.5	206.5	227.1									
Door Fan 3		A		[Pa]																
Door Fan 3				91.1	108.3	134.4	155.3	176.8	194.8	217.0	227.7									
Door Fan 4		A		[Pa]																
Door Fan 4				98.4	114.5	138.3	158.1	180.3	200.0	224.0	242.2									
Door Fan 5		A		[Pa]																
Door Fan 5				71.6	89.3	111.7	129.7	152.2	171.2	196.0	215.4	115.6	126.4	140.4	155.5					
Door Fan 6		A		[Pa]																
Door Fan 6				87.5	107.7	138.5	163.0	193.9	222.2	262.4	309.0									
Door Fan 1		Open(22)		[Pa]																
Door Fan 1												68.8	74.3	80.5	88.2					
Door Fan 2		Open(22)		[Pa]																
Door Fan 2												62.9	68.2	77.2	84.1					
Door Fan 4		Open(22)		[Pa]																
Door Fan 4												63.3	68.0	75.1	82.4					
Door Fan 5		Open(22)		[Pa]																
Door Fan 5																				
Door Fan 6		Open(22)		[Pa]																
Door Fan 6												105.6	118.5	133.4	148.7					
Door Fan 3		Open(22)		[Pa]																
Door Fan 3												70.7	77.5	85.5	93.5					
											Time per Building Pressure		20 sec.							
Bias pressure, final [Pa]				.206	.224	.345	-.018	-.038	-.17	-.149	.234	.132	.236	.129	.381					
											Temperature, final		indoors 75 °F		outdoors 87 °F					

Types of door fan tests 3



Questions?
Comments?
Angry rants?