

RESNET/ICC 301-2014 Addendum T-201x

Thermal Distribution System Efficiency

ANSI Approval Date November 29, 2018

Effective Date December 29, 2018

No Transition Period

Modify the current Standard ANSI/RESNET/ICC 301-2014 Table 4.2.2(1) language from Addendum D-2017 as follows:

Table 4.2.2(1)

Thermal distribution systems:	Thermal distribution system efficiency (DSE) of 0.80 shall be applied to both the heating and cooling system efficiencies.	For forced air distribution systems: Tested in accordance with requirements of Standard ANSI/RESNET/ICC 380-2016 or equivalent ^(m) and then either calculated through hourly simulation or calculated in accordance with ASHRAE Standard 152-2004 and calculated with the ducts located and insulated as in the Rated Home. For ductless distribution systems: DSE=1.00 For hydronic distribution systems: DSE=1.00
-------------------------------	--	---

