

## Rater Field Data Collection Form

**Address of Rated Home**

**6311 Irving Ave. S. Richfield, MN 55423**

**Name of Verifier**

**Slimothy Pickens**

**Date of Final Inspection**

**8/25/2021**

<b>Building Component</b>	<b>Rater Field Verified</b>	<b>Notes</b>
Building Dimensions	Verified	All building dimensions including fenestration match plans
Foundation Type	cond. Basement	bsmt slab 7ft below grade
Slab Insulation	R-10 under	
Foundation Walls	R10 exterior foam, R5 interior foam	
Frame Floor Assembly	NA	
Rim/Band Joist	R20 Spray Foam	See Pic
Above Grade Wall Assembly	2x4 R13 FB, 16"O.C.+ R5 Exterior foam	Grade I per pre-drywall inspection
Ceiling Assembly	2x8 Ceiling Joist, R49 blown	Grade I, See Pic
Roof Assembly	gable roof, 2x12 Rafters 24" O.C.	
Attic Type	Vented	
Doors	R5 Foam Core	
Glazing	Low e- vinyl U=.28/SHGC= .29	
Skylights	NA	
ACH	Tested	See Multipoint Test Report
Duct LTO	Tested	See Pic
Mechanical Ventilation	CFIS	109cfm, 12hrs/day, 311 Fan Watts
Space Heating	Gas Furnace	See AHRI Cert
Space Cooling	AC split system	See AHRI Cert and pics
Domestic Hot Water	Storage Natural Gas	See AHRI Cert and pics
Thermostat	prog	See Pic
Lighting	All LED	See Pics
Orientation (Front/street)	East	
Washer	NA	See Pic
Dryer	NA	See Pic
Refrigerator	NA	See Pic
Dishwasher	Installed	See Pic
Ceiling Fans	NA	See Pic
PV/Site Generation	NA	See Pic